

PAT Report Passes And Fails For all Sites and Locations

CLIENT DETAILS	
Company Name:	Afrasia Ltd
Address:	2 Tewkesbury Road Cheltenham Glos GL51 9FD



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING		
Company Name:	Gloucestershire PAT Testing	
Address:	12 Kingsholm Square Gloucester Glos GL1 2QJ	Telephone: 0843 289 6116
		Mobile: 07730 572380
		Email: info@glospat.co.uk
		Web: www.gloucestershirepattesting.co.uk
Cert Number:	003220	Signature: 
Order Number:		
File Name:	Afrasia Ltd 2025.PAT	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
- STORAGE									
277369	DDJ CONTROLER	13/05/25	P	S	S	P >19.9	S	P <0.10	PASS
277370	COLD SPARK	13/05/25	P	S	P 0.07	P >19.9	S	P 0.62	PASS
277371	COLD SPARK	13/05/25	P	S	P 0.07	P >19.9	S	P 0.76	PASS
277372	COLD SPARK	13/05/25	P	S	P 0.07	P >19.9	S	P 0.78	PASS
277373	COLD SPARK	13/05/25	P	S	P 0.07	P >19.9	S	P 0.81	PASS
277374	UP LIGHTER	13/05/25	P	S	P 0.06	P >19.9	S	P 0.15	PASS
277375	UPLIGHTER	13/05/25	P	S	P 0.06	P >19.9	S	P 0.16	PASS
277376	UPLIGHTER	13/05/25	P	S	P 0.06	P >19.9	S	P 0.16	PASS
277377	UPLIGHTER	13/05/25	P	S	P 0.06	P >19.9	S	P 0.15	PASS
277378	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.16	PASS
277379	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.16	PASS
277380	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.15	PASS
277381	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.16	PASS
277382	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.16	PASS
277383	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.16	PASS
277384	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.15	PASS
277385	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.14	PASS
277386	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.14	PASS
277387	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.16	PASS
277388	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.15	PASS
277389	UPLIGHTER	13/05/25	P	S	P 0.07	P >19.9	S	P 0.16	PASS
277390	AMPLIFIER X1500	13/05/25	P	S	P 0.08	P >19.9	S	P 0.38	PASS
277391	NEXO AMP	13/05/25	P	S	P 0.08	P >19.9	S	P 1.08	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
277392	POWER CON	13/05/25	P	S	S	S	S	S	PASS	
	VISUAL INSPECTION ONLY									
277393	POWER CON	13/05/25	P	S	S	S	S	S	PASS	
	VISUAL INSPECTION ONLY									
277394	EQUALISER	13/05/25	P	S	S	P >19.9	S	P <0.10	PASS	
	NO EXPOSED EARTH POINT									
277395	DISTRIBUTOR	13/05/25	P	S	S	S	S	S	PASS	
	VISUAL INSPECTION ONLY									
277396	TELEVISION	13/05/25	P	S	S	P >19.9	S	P <0.10	PASS	
277397	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS	
277398	PRX535	13/05/25	P	S	P 0.10	P >19.9	S	P 1.45	PASS	
277399	PRX535	13/05/25	P	S	P 0.08	P >19.9	S	P 1.44	PASS	
277400	HAZE MACHINE	13/05/25	P	S	P 0.07	P >19.9	S	P 0.34	PASS	
277401	STARCLOTH	13/05/25	P	S	S	P >19.9	S	P <0.10	PASS	
277402	RX1	13/05/25	P	S	S	P >19.9	S	P 1.26	PASS	
	NO EXPOSED EARTH POINT									
277403	RX1	13/05/25	P	S	S	P >19.9	S	P 1.65	PASS	
	NO EXPOSED EARTH POINT									
277404	RX1	13/05/25	P	S	S	P >19.9	S	P 1.49	PASS	
	NO EXPOSED EARTH POINT									
277405	RX1	13/05/25	P	S	S	P >19.9	S	P 1.05	PASS	
	NO EXPOSED EARTH POINT									
277406	RX1	13/05/25	P	S	S	P >19.9	S	P 1.22	PASS	
	NO EXPOSED EARTH POINT									
277407	RX1	13/05/25	P	S	S	P >19.9	S	P 1.51	PASS	
	NO EXPOSED EARTH POINT									
277408	RX1	13/05/25	P	S	S	P >19.9	S	P 1.51	PASS	
	NO EXPOSED EARTH POINT									
277409	RX1	13/05/25	P	S	S	P >19.9	S	P 1.25	PASS	
	NO EXPOSED EARTH POINT									
277410	RX1	13/05/25	P	S	S	P >19.9	S	P 1.17	PASS	
	NO EXPOSED EARTH POINT									
277411	RX1	13/05/25	P	S	S	P >19.9	S	P 1.51	PASS	
	NO EXPOSED EARTH POINT									
277412	RX1	13/05/25	P	S	S	P >19.9	S	P 1.31	PASS	
	NO EXPOSED EARTH POINT									
277413	RX1	13/05/25	P	S	S	P >19.9	S	P 1.41	PASS	
	NO EXPOSED EARTH POINT									
277414	RX1	13/05/25	P	S	S	P >19.9	S	P 1.23	PASS	
	NO EXPOSED EARTH POINT									
277415	RX1	13/05/25	P	S	S	P >19.9	S	P 1.25	PASS	
	NO EXPOSED EARTH POINT									
277416	RX1	13/05/25	P	S	S	P >19.9	S	P 1.42	PASS	
	NO EXPOSED EARTH POINT									
277417	RX1	13/05/25	P	S	S	P >19.9	S	P 1.54	PASS	
277418	FAN	13/05/25	P	S	P 0.07	P >19.9	S	P <0.10	PASS	
277419	LOW FOG	13/05/25	P	S	S	P >19.9	S	P 0.12	PASS	
277420	WIRELESS MIC	13/05/25	P	S	S	P >19.9	S	P <0.10	PASS	
277421	POWERCON	13/05/25	P	S	S	S	S	S	PASS	
	VISUAL INSPECTION ONLY									
277422	POWERCON	13/05/25	P	S	S	S	S	S	PASS	
	VISUAL INSPECTION ONLY									

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
277423	POWERCON	13/05/25	P	S	S	S	S	S	PASS
VISUAL INSPECTION ONLY									
277424	POWERCON	13/05/25	P	S	S	S	S	S	PASS
VISUAL INSPECTION ONLY									
277425	EXTENSION CABLE 2 WAY	13/05/25	P	P	P 0.10	P >19.9	S	S	PASS
277426	EXTENSION CABLE 2 WAY	13/05/25	P	P	P 0.08	P >19.9	S	S	PASS
277427	EXTENSION CABLE 2 WAY	13/05/25	P	P	P 0.07	P >19.9	S	S	PASS
277428	EXTENSION CABLE 2 WAY	13/05/25	P	P	P 0.09	P >19.9	S	S	PASS
277429	EXT CABLE 6 WAY	13/05/25	P	P	P 0.03	P >19.9	S	S	PASS
277430	EXT CABLE 6 WAY	13/05/25	P	P	P 0.05	P >19.9	S	S	PASS
277431	EXT CABLE 6 WAY	13/05/25	P	P	P 0.05	P >19.9	S	S	PASS
277432	EXT CABLE 6 WAY	13/05/25	P	P	P 0.03	P >19.9	S	S	PASS
277433	EXT CABLE 6 WAY	13/05/25	P	P	P 0.05	P >19.9	S	S	PASS
277434	EXT CABLE 6 WAY	13/05/25	P	P	P 0.04	P >19.9	S	S	PASS
277435	EXT CABLE 6 WAY	13/05/25	P	P	P 0.03	P >19.9	S	S	PASS
277436	POWERCON	13/05/25	P	S	S	S	S	S	PASS
VISUAL INSPECTION ONLY									
277437	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277438	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277439	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277440	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277441	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277442	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277443	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277444	IEC	13/05/25	P	P	P 0.03	P >19.9	S	S	PASS
277445	IEC	13/05/25	P	P	P 0.03	P >19.9	S	S	PASS
277446	IEC	13/05/25	P	P	P 0.06	P >19.9	S	S	PASS
277447	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277448	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277449	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277450	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS
277451	IEC	13/05/25	P	P	P 0.02	P >19.9	S	S	PASS

Total Appliances > **83**

Total Appliances For Report: 83